



GOVT. APPROVED
TEST HOUSE

STANDARD ANALYTICAL LABORATORY (ND) PVT. LIMITED

9, 69, F.I.E, Patparganj, Delhi-92

Ph. : 011-45130672, 011-40520672

+91 9811110632, 9811110672

E-mail : info@testinglaboratoryindia.com

website : www.testinglaboratoryindia.com



SAL/QF/38

TEST REPORT

Sample Name	PRINKING WATER.	Mfg Lic No	N.S.	
Submitted By	JALNOW.	Report No	SALM01072026007	
Address	Krishna Nagar, AramPark, Delhi-110051.	Receipt Date	01-Jul-26	
Mfg By	N.S.	Report Date	06-Jul-26	
Supplied By	N.S.	Ref No	N.S.	
Batch No	Mfg. Date	Exp Date	Batch Size	Sample Qty
1	N.S.	N.S.	N.S.	01 LTR.

TEST RESULTS

Date / Period of Performance of test 01/07/2026 to 06/07/2026.

Reference to protocol :- IS : 10500-2012. (ESSENTIAL PARAMETERS)

ORGANOLEPTIC & PHYSICAL PARAMETERS			limit	Test Method
S.No.	Test result	Desirable)	(Permissible)	
1. Colour (Hazen units, max.)	:- Less than 1.0 5		(May be extended up to 15 only if toxic substances are not suspected, in the absence of alternate sources.)	IS:3025 (P-4)
2. Odour	:- Agreeable	Agreeable	Agreeable	IS:3025 (P-5)
3. Taste	:- Agreeable	Agreeable	Agreeable	IS:3025 (P-8)
4. Turbidity (NTU), Max.	:- Less than 1.0 1		(May be extended up to 5 in absence of alternate sources)	IS:3025 P-10)
5. pH Value	:- 7.1	6.5 to 8.5	(No relaxation)	IS:3025 (P-11)
6. Total Dissolved Solids:- mg/L, Max.	50.8mg/l	500	(May be extended up to 2000 in absence of alternate source)	IS:3025 (P-16)
CHEMICAL TESTS				
7. Chlorides (as Cl) mg/L, Max	:- 27.4mg/l	250	(May be extended up to 1000 in absence of alternate source)	IS:3025 (P-32)
8. Total Hardness (as CaCO ₃) mg/L, Max	:- 48.6mg/l	200	(May be extended up to 600 in absence of alternate source)	IS:3025 (P-21)



STANDARD ANALYTICAL LABORATORY (ND) PVT. LIMITED

69, F.I.E, Patparganj, Delhi-92
Ph : 011- 45130672, 011-40520672
+91 9811110632, 9811110672
E-mail : info@testinglaboratoryindia.com
website : www.testinglaboratoryindia.com

GOVT. APPROVED
TEST HOUSE



SAL/QF/38

TEST REPORT

Sample Name PRINKING WATER.

Submitted By JALNOW.

Address Krishna Nagar, AramPark, Delhi-110051.

Mfg By N.S.

Supplied By N.S.

Batch No

1

Mfg. Date *

N.S.

Exp Date

N.S.

Batch Size

N.S.

Mfg Lic No N.S.

Report No SALM01072026007

Receipt Date 01-Jul-26

Report Date 06-Jul-26

Ref No N.S.

Sample Qty

01 LTR.

9. Iron (as Fe)mg/L,Max :- BDL 0.3
(MDL-0.02)

No relaxation IS:3025
(P-53)

10. Fluoride, (as F) mg/L,Max :- BDL 1.0
(MDL-0.01)

(May be extended up IS:3025
to 1.5 in absence (P-60)
of alternate source)

11. Calcium (as ca)mg/L,Max:- 11.0mg/l 75

(May be extended up IS:3025
to 200 in absence (P-40)
of alternate source)

12. Magnesium (as Mg)mg/L,Max:-3.4mg/l 30

(May be extended up IS:3025
to 100 in absence (P-46)

13. Sulphate(as SO_4) :- 11.4mg/l 200 400

IS:3025

14. Residual Free Chlorine:- BDL 0.2
mg/L,Min (MDL:0.1)

(May be extended up IS:3025
to 1.0 in absence (P-26)
of alternate source)

BACTERIOLOGICAL EXAMINATION :

a) Total coliform(cfu/100ml) :- Absent Absent
b) Escherichia Coli(cfu/100ml) :- Absent Absent

IS 15185-2016.

IS 15185-2016.

BDL-Below Detection Limit

MDL-Method Detection Limit

END OF TEST REPORT

Report: Complies as per IS : 10500-2012.with respect to above tests only.

VINIT
Person in Charge Of Testing